


# WIN-911 Operator Workspace


The WIN-911 Operator Workspace can be started from an HMI display to provide a quick solution for making changes to notification policies and connection details without requiring administrator privileges.

## Install


Navigate to the *Support* folder of your install media and double-click the *WIN911.UserWorkspace.exe* file. This will bring up the *WIN-911 Operator Workspace – Setup*.




Click *Next >* to continue.



Review the Software License Agreement and click the "I accept ..." radio button then *Next >* to continue the installation.



Click *Install* to proceed with the installation.



Click *Finish* to complete the installation process.

The utility can now be accessed through your start menu.

## Introduction

The *WIN-911 Operator Workspace* is a tool that can be invoked independently of the WIN-911 Workspace and allow users to make live edits to callout lists. The utility facilitates the modification of *Notification Policy* and associated *Connections*. The user can add, remove, and rearrange the *Connections* in a callout list, change *Schedules*, and add/remove *Roles*.

The HMI administrator can create scripts within the HMI environment to launch the WIN-911 Operator Workspace. You can find examples for each HMI at [WIN911.com](http://WIN911.com).

The *WIN-911 Operator Workspace* can be found here: "C:\Program Files (x86)\WIN-911 Software\Operator Workspace\WIN911.OperatorWorkspace.exe"

The following is a generic example of a script to launch the WIN-911 Operator Workspace:

StartApp "C:\Program Files (x86)\WIN-911 Software\Operator  
Workspace\WIN911.OperatorWorkspace.exe";

## First Time Configuration

The first launch you will see an error unless WIN-911 is installed locally. To configure the utility to reference a remote WIN-911 installation, click the gear icon in the upper right and provide the WIN-911 host name or IP address.

## Notification Policies

The screenshot shows the 'Notification Policies' configuration window in the WIN-911 Operator Workspace. The window title is 'WIN-911 Operator Workspace'. At the top, there are two tabs: 'Notification Policies' (selected) and 'Connections'. On the right side of the top bar, there are icons for settings (gear) and help (?). Below the tabs, there is a dropdown menu labeled 'Select Notification Policy' with 'Inform Tank Operators' selected. Below this, there is a 'Details' section with a dropdown arrow. The main area contains a table with columns: 'Connection', 'Type', 'Connection String', 'Retries Upon Failure', 'Delay Between Retries', and 'Delay After Successful Notification'. The table has two rows of connections. Below the table, there are several control icons: a plus sign (+), a refresh icon, up and down arrows, a trash icon, a refresh icon, and a close icon (X).

Connection	Type	Connection String	Retries Upon Failure	Delay Between Retries	Delay After Successful Notification
<input type="checkbox"/> Ben W.	📧	ben.w@win911.com	0	0 Minutes	0 Seconds
<input type="checkbox"/> Steven R.	📧	steven.r@win911.com	0	0 Minutes	0 Seconds

Notification Policies are simple callout lists which deliver alarm notifications to the Connections listed within them. When a Notification Policy is started, the list of Connections is processed in the order they appear. Notifications are sent only to Connections which are on duty at the time the notification attempt is made. Also, notifications are processed synchronously, that is, WIN-911 waits for each notification attempt to be completed before it continues to its next action. In the event of a failure to send a notification to a Connection, additional attempts may be configured. Delays may be placed between attempts to notify a Connection and between different Connections.

## Editing the Notification Policy

### Select Notification Policy

Use the pulldown list to select the Notification Policy you want to modify.

## Repeats


Use the up/down arrows to enter the desired number of times you would like the policy to be repeated each time it is invoked.


## Delay Before Notification

Use the Minutes and Seconds spinners to specify the amount of time you would like the Notification Policy to wait before it begins notification tasking.

## Editing the Callout List

The callout list is conducted synchronously from top to bottom. A Connection can be entered any number of times.

Use the Add  button to add a connection to the callout list.

Use the Delete  button to remove a connection from the callout list.

Use the Up  and Down  buttons to rearrange the callout order.

## Connection

The name of the Connection to be notified.

## Type

This icon indicates the type of the Connection to be notified

## Retries

The number of additional attempts that should be made to notify the Connection, should failures occur.


## Delay Between Retries





The amount of time to wait between attempts to notify the Connection.

## Delay After Connection

The amount of time to wait after the Connection has been notified before moving on to the next entry in the list.

# Connections



Name	Type	Connection String	Can Acknowledge	Schedule	Roles
Ben W.		ben.w@win911.com	No	Always	+
Ben W.		5123261011	No	Always	+
Ben W.		ben.w@win911.com	Yes	Always	+
Steven R.		steven.r@win911.com	No	Always	+

Connections specify a destination for alarm notification. Connections are associated with a Schedule which determines their availability. They may also be assigned one or more Roles for organization or use with Role based notification of WIN-911 Advanced.

## Name

Each Connection must have a unique name (within its type) that identifies and distinguishes it from the others.

## Type

This icon indicates the type of the Connection to be notified. This field is not editable.

## Connection String

View the 'notifier specific' string that defines the individual that will receive the notification. This string will follow the established conventions mandated by the communication medium. For example, an email address or a phone number. This field cannot be edited.

## Schedule

Select the schedule that WIN-911 will honor when sending alarm and report messages. A Connection can have only one assigned schedule.

## Roles

Select Roles

Search

<input type="checkbox"/>	Roles	Description	▼
<input type="checkbox"/>	Managers	Managers of all levels	
<input checked="" type="checkbox"/>	Operators	Field Operators	

Roles represent a label for organizing connections based on availability, location, or responsibility. Roles can be used in an advanced notification policies to notify all Connections with something in common.